

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A 000              | <p>Initial Comments</p> <p>This is a 23 bed Specialty Care Assisted Living Facility (SCALF) with a census of 16 on October 23, 2025.</p> <p>Deficiencies were cited during this survey for failure to operate in accordance with the Rules of the Alabama State Board of Health (SBOH), Alabama Department of Public Health (ADPH), Chapter 420-5-20, Alabama Administrative Code, Specialty Care Assisted Living Facilities. The deficient practices require a plan of correction.</p>  | A 000         |   |                    |
| A 702              | <p>420-5-20-.07 (2) Food Service.</p> <p>(2) Food Handling Procedures.</p> <p>(a) Dish and Utensils Washing, Disinfection, and Storage.</p> <p>1. Wash water shall be changed with sufficient frequency to avoid gross contamination, and final rinse water shall be kept clean and clear.</p> <p>2. Hand washed repeated service and multi-service utensils and dishes, after washing and rinsing, shall be sanitized by either of the following methods:</p> <p>(i) Utensils and dishes shall be completely immersed for a period of not less than 30 seconds in water that is at least 171 degrees Fahrenheit (pouring scalding water over utensils and dishes does not meet this requirement); or</p> <p>(ii) A cold water sanitizer: A sanitizing solution shall be used in accordance with the manufacturers' instructions. Utensils and dishes shall be completely immersed for a period of not</p> | A 702         |   |                    |

Health Care Facilities  
LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE \_\_\_\_\_ TITLE \_\_\_\_\_ (X6) DATE \_\_\_\_\_

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A 702              | <p>Continued From page 1</p> <p>less than 10 seconds in a clean solution containing not less than 50 ppm, and not more than 200 ppm, of available chlorine bleach or its equivalent or 30 seconds 12.5 ppm of iodine or the amount of time specified by the manufacturer in a 200 ppm quaternary ammonium solution. Water temperature must be at least 75 degrees Fahrenheit. Water temperatures and chemical concentrations shall be monitored and documented prior to dishwashing. A record of each test shall be maintained for at least three months.</p> <p>3. Dishes and utensils shall be allowed to air dry.</p> <p>4. After washing, rinsing, sanitizing, and air-drying, all repeated use service ware (utensils and dishes) shall be stored in a clean, dry place that is protected from pests, dust, splash, and other contaminants. Utensils shall be handled in such a way as to prevent contamination from hands and clothing.</p> <p>5. The results from the use of dishwashing machines shall be equivalent to those obtained from the method outlined above, as documented in material provided from the manufacturer and kept on file at the facility.</p> <p>(b) Ice. Crushed or chipped ice shall be protected from splash, drip, and hand contamination during storage and service. The ice scoop shall be stored in a holder inside the ice bin in a manner to prevent ice from coming into contact with the handle, or it may be stored in an airtight container outside the ice bin.</p> <p>(c) Protection of Food from</p> | A 702         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 702              | <p>Continued From page 2</p> <p>Contamination.</p> <ol style="list-style-type: none"> <li>1. Food and food ingredients shall be stored, handled, and served so as to be protected from pests, dust, rodents, droplet infection, unsanitary handling, overhead leakage, sewage backflow, and any other contamination. Sugar, syrup, and condiment receptacles shall be provided with lids and shall be kept covered when not in use.</li> <li>2. Medications, biologicals, poisons, detergents, and cleaning supplies shall not be kept in the refrigerator nor in other areas used for storage of food.</li> <li>3. Food shall not be stored on the floor. All food and food ingredients stored on shelving must be placed on shelving that is at least six inches above the floor.</li> <li>4. Refrigerators shall maintain a maximum temperature of 41 degrees Fahrenheit. Freezers shall maintain at a maximum temperature of 0 degrees Fahrenheit. Thermometers shall remain in refrigerators and freezers at all times.</li> <li>5. All leftover foods shall be labeled and dated with a "use by date," so that it may be consumed or discarded by that date, which is no more than three days from the date it was prepared.</li> <li>6. All food products shall be used by the manufacturer's indicated date or discarded.</li> <li>7. Food shall be prepared either in the licensed facility or another location even when</li> </ol> | A 702         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 702              | <p>Continued From page 3</p> <p>that location is not part of the licensed facility. All food preparation areas used by the facility shall be subject to the same inspections as though part of the licensed facility. The licensed facility is responsible to ensure adequate equipment and measures are used so that food is not contaminated in transport and foods that are transported are held and served at the appropriate temperature at all times.</p> <p>8. Hot food shall be maintained at a minimum temperature of 135 degrees Fahrenheit and cold foods at a maximum temperature of 41 degrees Fahrenheit.</p> <p>9. Frozen food items (raw and cooked) shall be thawed under refrigeration or under running water prior to preparation. Frozen food may also be thawed as part of the cooking process when indicated by package directions. Raw meats shall be stored below and away from vegetables, fruits, and other foods to prevent contamination (meat juices dripping on other foods).</p> <p>10. Laundry shall not be brought through the food preparation or service area.</p> <p>(d) Storage and Service of Milk and Ice Cream.</p> <p>1. Milk and fluid milk products shall be served only from the original containers in which they were received from the distributor. This shall not apply to cream for coffee, cereals, and milk for milk drinks which may be dispensed from a readily cleanable container approved for such use.</p> | A 702         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 702              | <p>Continued From page 4</p> <p>2. Milk and fluid milk products shall be stored in such a manner that bottles or containers from which the milk or milk product is to be poured or drunk will not become contaminated from drip or contact with foods. Milk shall be maintained and stored at a maximum temperature of 41 degrees Fahrenheit and shall not be served at a temperature warmer than 45 degrees Fahrenheit unless specifically requested to be served at a warmer temperature by a resident.</p> <p>3. Contaminating substances shall not be stored with or over open containers of ice cream. Ice cream dippers, spatulas, and other serving utensils shall be cleaned between uses.</p> <p>(e) Kitchen Garbage and Trash Handling.</p> <p>1. Kitchen garbage and trash shall be placed in suitable containers with tight-fitting lids and properly stored pending removal. Kitchen garbage and trash shall not be allowed to accumulate in the kitchen and shall be removed from the premises at frequent intervals.</p> <p>2. After being emptied, all garbage cans and trash cans shall be washed and dried before reuse.</p> <p>(f) Employees' Cleanliness.</p> <p>1. Employees engaged in the handling, preparation, and serving of food shall wear clean clothing at all times. Employees shall wear hair restraints, for example, hairnets, headbands, caps, or other adequate means to prevent contamination of food from hair. Employees</p> | A 702         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A 702              | <p>Continued From page 5</p> <p>whose duties include contact with residents shall change clothing or wear a clean covering over clothing before handling, preparing, or serving food.</p> <p>2. Employees handling food shall wash their hands thoroughly before starting work each day, immediately after contact with any soiled matter, and before returning to work after each visit to the rest room.</p> <p>3. Street clothing not worn by the employee shall be stored in lockers, dressing rooms, or closets designated for staff use.</p> <p>(g) Live Fowl or Animals. Live fowl or animals shall not be allowed in the food service area.</p> <p>(h) Smoking and Spitting. Smoking, other use of tobacco products, and spitting within the food service area shall be prohibited for all staff, residents, and visitors.</p> <p>(i) Dining in Kitchen. Dining in the kitchen shall not be permitted in Congregate assisted living facilities.</p> <p>(j) Paper for Food Wrapping. Only new paper, foil, or plastic wrap shall be used for wrapping of foods.</p> <p>(k) Laundering of clothing shall not be permitted in food preparation or service areas.</p> <p>This Rule is not met as evidenced by:<br/>Based on observation and interview, the facility failed to ensure food items were stored in a</p> | A 702         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A 702              | Continued From page 6<br><br>manner to protect from potential contamination.<br><br>Findings:<br><br>On the morning of October 21, 2025, an observation was made of bowls of fruit in the cooler that were partially uncovered. On the afternoon of October 23, 2025, Employee Identifier (EI)#1 agreed the food should be protected from potential contamination.   | A 702         |   |                    |
| A 804              | 420-5-20-.08 (4) Physical Facilities.<br><br>(4) Food Service Facilities.<br><br>(a) Floors. Floors in food service areas shall be of such construction as to be easily cleaned, sound, smooth, non-absorbent, without cracks or crevices, and shall be provided with approved and conveniently located facilities for the disposal of floor wash water.<br><br>(b) Walls and Ceilings. Walls and ceilings of food service areas shall be of tight and substantial construction, and smoothly finished. The walls and ceilings shall be without horizontal ledges and shall be washable up to the highest level reached by splash and spray. Roofs and walls shall be maintained free of leaks. All openings to the exterior shall be provided with doors or windows, which prevent the entrance of rain or dust during inclement weather.<br><br>(c) Screens or Outside Openings. Openings to the outside shall be effectively screened, or suitable provisions made equal to screening (such as fly fans). Screen doors shall be equipped with self-closing devices. | A 804         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A 804              | <p>Continued From page 7</p> <p>(d) Lighting. The kitchen, dishwashing area, and the dining room shall have adequate light.</p> <p>(e) Ventilation. Vent/exhaust hoods, vented to the outdoors, shall be provided over cooking surfaces to aid in removing cooking odors. Group homes with residential stoves may use a residential hood sized for the stove. Commercial exhaust hoods shall be installed when commercial cooking equipment is used. Congregate facilities shall use a commercial exhaust hood system.</p> <p>(f) Employee Toilet Facilities. Toilet rooms, if provided, shall not open directly into any room or space in which food is prepared, stored, displayed, or served, nor into any room in which utensils are washed or stored. Toilet rooms shall include a lavatory with a soap dispenser and disposable towels, and shall be well lighted and ventilated.</p> <p>(g) Hand washing Facilities. Each Group and Congregate specialty care assisted living facility shall provide a hand washing lavatory in the kitchens which shall be equipped with a soap dispenser and a supply of soap, disposable towels, and hot and cold running water through a mixing valve or combination faucet. The use of a common towel and common bar soap is prohibited. Hands shall not be washed in sinks where food is prepared.</p> <p>(h) Refrigeration Facilities. Adequate refrigeration facilities, automatic in operation for the storage of perishable foods, shall be provided Refrigeration shall be maintained at 41 degrees Fahrenheit or less. All refrigerators shall be</p> | A 804         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 804              | <p>Continued From page 8</p> <p>provided with thermometers. All refrigerators shall be kept clean.</p> <p>(i) Equipment and Utensil Construction. Equipment and utensils, except single service utensils, shall be so constructed as to be easily cleaned and shall be kept in good repair. No cadmium plated, lead, or readily corrodible utensils or equipment shall be used.</p> <p>(j) Separation of Kitchen from Resident Rooms and Sleeping Quarters. Any room used for sleeping quarters shall be separated from the food service area by a solid wall with no direct openings. Sleeping accommodations shall not be permitted within the food service area.</p> <p>(k) Clean Rooms. Floors, walls, and ceilings of rooms in the food service area shall be clean and free of an accumulation of rubbish, dust, grease, dirt, etc.</p> <p>(l) Clean Equipment. Equipment in the food service area shall be clean and free of dust, grease, dirt, etc.</p> <p>(m) Clean Counters, Tables, Tablecloths, and Napkins. Tables and counters, which are used for food service, shall be kept clean. Tablecloths and cloth napkins shall be laundered after each use.</p> <p>(n) Location and Space Requirements. Food service facilities shall be located in a specifically designated area and shall include the following rooms and space: kitchen, dishwashing, food storage, and dining room.</p> <p>(o) Equipment. Minimum equipment in</p> | A 804         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 804              | <p>Continued From page 9</p> <p>the kitchen shall include the following:</p> <ol style="list-style-type: none"> <li>1. Range. In a Group specialty care assisted living facility, a residential use range is permitted. A Congregate specialty care assisted living facility shall have a heavy duty range suitable for institutional use with double oven, or equivalent.</li> <li>2. Refrigerator. A Group specialty care assisted living facility may use a residential refrigerator. A Congregate specialty care assisted living facility shall have a heavy-duty refrigerator suitable for institutional use.</li> <li>3. Fire extinguisher. Five-pound type BC for residential hoods and K type for commercial hoods.</li> <li>4. Dishwashing. The dishwashing equipment for Group assisted living facilities shall be either residential type using cold water sanitizers or commercial type with a booster water heater. Dishwashing equipment for all Congregate assisted living facilities shall be commercial type using a booster water heater or an automatic dispensing sanitizing chemical system.</li> <li>5. A three-compartment sink with a booster heater or chemical sanitizing system for the third compartment shall be provided in Congregate assisted living facilities.</li> <li>6. Garbage cans with cover.</li> </ol> <p>(p) Food Storage. A well-ventilated, cool food storage room, pantry, or cabinets shall be provided. Adequate shelving, bins, suitable cans,</p> | A 804         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 804              | <p>Continued From page 10</p> <p>and raised platforms shall be provided and kept clean. Perishable food shall be stored at least six inches above the floor. The storeroom shall be of such construction as to prevent the invasion of rodents and insects, the seepage of dust and water, leakage, or any other source of contamination.</p> <p>(q) Dining Room.</p> <p>1. A resident dining room, or rooms, shall be provided which is large enough to seat not less than 100 percent of the bed capacity.</p> <p>(r) Water Heating Equipment.<br/>Equipment for heating an ample supply of water, under pressure, for all washing purposes shall be provided. Hot water shall be piped to all hand-washing facilities, and to each compartment of all dishwashing and laundry sinks. Water heaters shall be of the automatic type.</p> <p>This Rule is not met as evidenced by:<br/>Based on observation and interview, the facility failed to ensure the ice machine was maintained to be free of a mold-like substance. Also a heavy accumulation of dust and dirt like particles and black mold-like debris were found on the ceiling above clean dishes.</p> <p>Findings:</p> <p>ICE MACHINE<br/>On the afternoon of October 20, 2025, the ice</p> | A 804         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A 804              | <p>Continued From page 11</p> <p>machine, used when serving ice to residents, was found with a heavy accumulation of pink and black mold-like substance on the inside of the ice storage.</p> <p><b>CEILING</b><br/>On the morning of October 21, 2025, an observation was made of dust and debris hanging from the ceiling near the air conditioner vents in the kitchen above clean dishes. Also, there was a buildup of black mold-like substance on the ceiling tiles around those vents above the clean dishes. EI#8 who was present for this observation said he would get the ceiling cleaned.</p> <p>On the morning of October 21, 2025, EI#1 said the ice machine had been cleaned and a cleaning schedule would be implemented.</p> | A 804         |   |                    |
| A1203              | <p>420-5-20-12 (5) Physical Environment.</p> <p>(5) General Building Requirements - Group and Congregate.</p> <p>(a) Structural Soundness and Repair. The building shall be structurally sound, free from leaks and excessive moisture, in good repair, and painted with sufficient frequency to be reasonably attractive inside and out. The interior and exterior of the building shall be kept clean and orderly.</p> <p>(b) Temperature to be Maintained. The facility shall maintain a comfortable temperature. A comfortable range is between 71-81 degrees Fahrenheit.</p> <p>(c) Lighting. Each resident's room shall have artificial light adequate for reading and other uses as needed. All entrances, hallways,</p>               | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A1203              | <p>Continued From page 12</p> <p>stairways, inclines, ramps, cellars, attics, storerooms, kitchens, laundries, and service units shall have sufficient artificial lighting to prevent accidents and promote efficiency of service. Night lights shall be provided in all hallways, stairways, and bathrooms.</p> <p>(d) Screens. All screen doors and operable windows shall be equipped with tight-fitting, full-length 16 mesh screens. Screen doors shall be equipped with self-closing devices.</p> <p>(e) Emergency Lighting.</p> <p>1. All specialty care assisted living facilities shall provide an emergency artificial lighting system to adequately illuminate halls, corridors, and stairwells in case of electrical power failure. As a minimum, dry cell battery-operated lighting shall be provided to light such spaces.</p> <p>2. Emergency lighting must provide illumination in accordance with the currently adopted Life Safety Code for at least 90 minutes.</p> <p>(f) Floors.</p> <p>1. All floors shall be level, smooth and free of cracks, and finished so as to be easily kept clean. The basic requirement for floor finishes shall be wall-to-wall with such finishes as paint, stain, sealer, carpet, sheet vinyl, vinyl tile, hard tile, or other appropriate floor finish.</p> <p>2. Any differences in floor levels shall not prevent a resident from navigating safely throughout the facility.</p> | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A1203              | <p>Continued From page 13</p> <p>(g) Walls and Ceilings. All walls and ceilings shall be of sound construction with an acceptable surface and shall be kept clean and in good repair.</p> <p>(h) Windows. Operable windows shall be so constructed and maintained so that they fit snugly, and are capable of being opened and closed easily. Windows in specialty care facilities may have devices which prevent full opening of the window.</p> <p>(i) Ceiling Height. Each room occupied by residents shall have a ceiling height of eight feet or more. Existing facilities with ceiling heights less than eight feet shall be acceptable when the height complies with the codes.</p> <p>(j) Handrails. If handrails are installed in halls or corridors, the handrails shall be mounted at 30 - 36 inches above the floor and returned to the wall at each end.</p> <p>(k) Stairways. Stairways shall be well lighted, kept in good repair, and have handrails. Open space under stairs shall not be used for storage purposes. All walls and doors under stairs shall meet the same fire rating as the stairwell.</p> <p>(l) Doors.</p> <p>1. In each new specialty care assisted living facility, doors of resident bathrooms connected to resident bedroom shall swing into the bedroom.</p> <p>2. Bedroom and bathroom doors may</p> | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A1203              | <p>Continued From page 14</p> <p>be equipped with hardware that will permit a resident to lock himself within the room, provided a master key is readily accessible for the staff at a central location.</p> <p>3. Resident bedroom and other exit access doors in specialty care assisted living facility shall be at least three feet wide.</p> <p>4. Exterior egress doors except the main entry/exit door, may be equipped with a delayed egress locking system installed in accordance with NFPA 101. Other exterior egress doors may be arranged to prevent free and unhindered egress from specialty care assisted living facilities, in accordance with the Special Requirements portion of this section.</p> <p>5. Exit doors swinging outward shall swing out over a landing having a minimum length and width equal to the door's width at the same level as the floor level, except existing doors shall not have more than a four inch step down.</p> <p>(m) Ventilation. The building shall be well ventilated at all times to prevent accumulation of objectionable odors. Kitchens, laundries, service rooms, toilets, and bathrooms shall be ventilated by windows, gravity vents, or mechanical means as necessary to prevent offensive odors from entering other parts of the facility.</p> <p>(n) Fire Extinguishers. Fire extinguishers shall be provided for each hall, kitchen, and laundry, of type and capacity appropriate to the need.</p> | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A1203              | <p>Continued From page 15</p> <p>1. Each fire extinguisher shall receive an annual inspection with maintenance, and recharging when necessary, by a fire equipment servicing representative. An annual servicing tag shall be attached to the extinguisher reflecting the name of the servicing company, representative, day, month, and year of maintenance.</p> <p>2. A visual inspection of each fire extinguisher shall be conducted monthly by a designated staff of the facility and documented on the attached extinguisher tag by the designated staff person.</p> <p>(o) Call System. A central electric or electronic call system shall be conveniently provided for each resident, usable in bedrooms and bathrooms. The call system shall be certified to meet the applicable Underwriters Laboratories standard.</p> <p>(p) Manufactured homes/mobile homes are not permitted.</p> <p>(q) Fireplaces and inserts shall be inspected and cleaned annually, and shall comply with the currently adopted building code. Openings shall be protected with screens or doors.</p> <p>(r) Exit marking. In all facilities, a sign bearing the word "EXIT" in plain legible block letters shall be placed at each exit. Additional signs shall be placed in corridors and passageways wherever necessary to indicate the direction of exit. Letters of signs shall be at least four inches high. All exit and directional signs shall be kept clearly legible by continuous internal electric illumination and have battery back-up or</p> | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)  | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|---|---------------|---|--------------------|
| A1203              | <p>Continued From page 16</p> <p>emergency power.</p> <p>(s) Heating, Lighting, and other Service Equipment.</p> <p>1. Central or individual room gas heating systems shall be of the enclosed flame type equipped with automatic flame shut-off control and shall be vented directly to the outside. Heating units of any type shall be located to avoid direct contact with any combustible material and shall be maintained in accordance with manufacturer's recommendation.</p> <p>2. Open flame and portable heaters are prohibited in specialty care assisted living facilities. This does not apply to a fire place with gas logs protected as noted elsewhere in these rules.</p> <p>3. Lighting shall be restricted to electricity. Electric wiring, motors, and other electrical equipment in all specialty care assisted living facilities shall be in accordance with local electrical codes and the NFPA National Electrical Code.</p> <p>This Rule is not met as evidenced by:<br/>Based on observation, record review and interview, the facility was not maintained in good repair, to provide a safe, functional, sanitary, decent and comfortable environment for residents, staff and visitors.</p> <p>Findings:</p> <p>CARPET<br/>On the morning of October 21, 2025, the surveyor</p> | A1203         |   |                    |

Alabama Department of Public Health

|  |  |   |   |
|--|--|---|---|
| STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION | (X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER:<br><br><b>P4911</b> | (X2) MULTIPLE CONSTRUCTION<br>A. BUILDING: _____<br><br>B. WING _____ | (X3) DATE SURVEY COMPLETED<br><br><b>10/23/2025</b> |
|--|--|---|---|

|   |   |
|---|---|
| NAME OF PROVIDER OR SUPPLIER<br><br><b>KAUHALE HERITAGE WOODS SCALF</b> | STREET ADDRESS, CITY, STATE, ZIP CODE<br><b>3440 HILLCREAST ROAD<br/>MOBILE, AL 36695</b> |
|---|---|

| (X4) ID PREFIX TAG | SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)   | ID PREFIX TAG | PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY) | (X5) COMPLETE DATE |
|--------------------|--|---------------|---|--------------------|
| A1203              | <p>Continued From page 17</p> <p>observed the facility's worn and dirty carpet. On the morning of October 23, 2025, EI#1 was asked to describe the facility carpet. EI#1 responded it was worn and old. EI#1 acknowledged the carpet was original from when the facility was built 25 years ago.</p> <p><b>MISSING PAINT AND HOLES IN THE CEILING</b><br/>On the afternoon of October 21, 2025, an observation was made of the ceiling where lights had been changed out. The area where the previous square fixtures had been was a different shade of paint than the rest of the ceiling. The small and larger holes in the ceiling where the previous fixtures had been attached were left open.</p> <p>On the afternoon of October 23, 2025, EI#1 agreed the area where the lights had been needed to be painted.</p> <p><b>THERESA HARRISON, REGISTERED NURSE</b></p> | A1203         |   |                    |